

June 24, 2020

North Hampton Library Trustees
237A Atlantic Ave
North Hampton, NH 03862

**RE: Response to RPC Review Letter
North Hampton Public Library, 239 Atlantic Ave, North Hampton, NH**

Dear Trustees:


Wilcox & Barton, Inc. is pleased to submit this letter addressing comments provided by the Rockingham Planning Commission in a review memo dated June 1, 2020. We offer the following:

6. **Stormwater Management:** We reviewed the proposed drainage controls and revised the Grading & Drainage Plan to increase on-site retention of post-development runoff. Grading north of the center walkway was revised to create stormwater storage and promote infiltration and groundwater recharge. The stone infiltration strip at the end of the parking has been expanded. The patio material was changed to permeable pavers to allow stormwater infiltration. Operation and Maintenance information for the stormwater gallery has been provided to the Library Trustees.
8. **Utilities:** On Sheet C0.1, the note has been corrected to reference Aquarion Water.

If you have any questions, or require additional information, please contact me at (603) 731-9883.

Very truly yours,

WILCOX & BARTON, INC.



Erin R. Lambert, P.E, LEED AP
Associate Vice President

Attachment: Site Plans